



CERTIFICATE

EC-Type examination certificate 6319-10

Manufacturer : Inepro Metering BV
Contact person : D. van der Vaart
Address : P.O. Box 92
Postal code, Place : 2450 AB, Leimuiden
Country : The Netherlands

Instrument : Electronic single-phase two-wire energy meter
Direct connected

Mark - Type : PRO-1TE PRO1D
Register : Mechanical LCD
Accuracy Class : B
Measurement range : 230 V
5(45) A
50 Hz
2000 imp./kWh

Temperature range : -10..40 °C
Use : Indoor
Protection Class : II
Environmental class : M1, E2
Registry method : bidirectional method with always positive register: the meter always counts the energy of the measuring point as received energy, irrespective of the real energy direction

The energy meter meets the requirements of Directive 2004/22/EC of the European parliament and the council of 31 March 2004 on measuring instruments.


Certification was based on compliance with the following harmonised standards:

EN 50470-1 (2006) : Electricity metering equipment (a.c.)-part 1: General requirements, tests and test conditions - Metering equipment (class indexes A, B and C)
EN 50470-3 (2006) : Electricity metering equipment (a.c.)-part 3: Particular requirements - Static meters for active energy (class indexes A, B and C)

Valid until : March 30, 2020

The results are recorded in the following annex: test report 2113897-TDT 6319-10.

KEMA Quality B.V.
Arnhem, March 30, 2010


ir. A.P.M. Baars
Certification manager
Notified body number 0344

The investigation reported here does not confer any right to use an approbation mark granted by KEMA.

Integral publication of this certificate and adjoining reports is allowed.
This certificate is issued provided that neither KEMA nor the RvA assumes any liability.

KEMA Nederland B.V. Utrechtseweg 310, 6812 AR Arnhem, The Netherlands P.O. Box 9035, 6800 ET Arnhem, The Netherlands
T +31 (0)26 3 56 2215 F +31 (0)26 4 42 6211 KAL@kema.com www.kema.com handelsregister Arnhem 09080262


ir. P.J.J.G. Nabuurs
Managing Director